VEHICLES USED FOR DISPLAY ON EXHIBIT FLOOR REGULATIONS

In Oklahoma, vehicles displayed on an exhibit floor are regulated by the International Fire Code (IFC).

Key regulations enforced include:

- **Fuel Limitation:** Fuel tanks must contain the minimum amount necessary for positioning or a maximum of 5 gallons (whichever is less).
- **Fuel Cap:** Fuel tank openings must be locked or sealed (typically with tape) to prevent the escape of vapors.
- **Battery:** At least one battery cable (usually the negative) must be disconnected and taped to prevent the engine from starting.
- **Keys:** Ignition keys must be removed and in the possession of a responsible person (often show management or security).
- **Inspections:** Vehicles are subject to inspection by the fire marshal.
- **Prohibitions:** Fueling or de-fueling of vehicles is prohibited inside the building.
- **Safety Measures:** Plastic sheeting is required beneath the vehicle. (ORA to provide)
- Three (3) feet of clear access is required around the vehicle.

Please contact Andrea Dancer at ~~a~~andrea@oklahomahospitality.com or Collin Graham ~~at c~~collin@oklahomahospitality.com or by phone at 405-942-8181 if you have any questions.